



The sensor can be fitted directly to the luminaire either on the inside or outside the luminaire, the PIR lens must have a clear view outside. If flush mounting in a panel >6mm thick, remove bottom of retention arms with side cutters. The detector should be sited so that the occupants of the room fall inside the detection pattern. Note the lower the sensor is mounted the smaller the detection range will be.

