



Do not site within 1 Meter of forced heating/ cooling ventilation. To flush mount Cut a 64mm hole in the ceiling. The sensor can also be mounted in an optional EBDBB Back box. Note that the lower the sensor is mounted the smaller the detection range will be.

Rear view of sensor

