



Do not site within 1 meter of any lighting or ventilation equipment, do not fix to a vibrating surface, site as far away from any metal surface as possible, do not fix to suspended light fitting. When used in a corridor or isle the sensor should be mounted at the end of the corridor or isle with the detector head directed down the corridor or isle.

Rear view of sensor

