



The PRE5709 Time Clock should be used in a suitable DIN rail enclosure with minimum protection grade IP20. Place the timer in a suitable enclosure. Connect power to terminal 1 and 2 of the timer (not polarity sensitive). The live connector must be protected with a MCB of a maximum rating of 16A.

