



Mount the TX unit at chest height. Mount the RX close to the Main supply of the unit which is to be controlled, Ideally mount next to the consumer unit. When switching 230V AC ensure the link between "Live" and "COM" is fitted.

